

Letter No. MED/126/2025

Date 12/09/2025


Certificate Regarding Drinking Water,,Sanitary and Health

To Whom So It Ever May Concern

Certify that a good Sanitary and Health condition is maintained in the Premises of Sr. Sec. Delhi Public School, Darshan Nagar Fatehpur, Sheohar Bihar, Pin Code – 843329.

The School has also provided separate staff to maintain sanitary condition on the school campus.


PRINCIPAL
SR. SEC. DELHI PUBLIC SCHOOL
FATEHPUR, SHEOHAR


Medical/Health Officer
Primary Health Centre
Patna(Bihar)


Government of Bihar
 DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL) PATNA
 Public Health Engineering Department
DRINKING WATER QUALITY TEST REPORT

Name of District : SHEOHAR
 Sampling Date : 12/10/2025
 Name of Person/ Organization : SR.SEC. DELHI PUBLIC SCHOOL
 Block: SHEOHAR
 Nagar Panchayat : SHEOHAR

Sample Collected By: Lab. Assistant
 Date of Analysis Completed: 16/10/2025

Sl.No.	Parameter	Desirable Limit (Value of mg/l except pH)	Permissible Limit to Absence of Alternate Source	Method of testing Parameters	Hand pump / Boring (Result in mg/l)	Remarks
1	Turbidity	5.0 NTU	10.0 NTU	Nephelometric	3 NTU	Analysed sample of water conforms to Indian standard limit
2	PH	6.5 – 8.5	No relaxation	pH meter	7.42	
3	Conductivity			Conductivity meter	310	
4	Total Hardness	200	600	EDTA method	400	
5	Alkalinity	200	600	Imation	450	
6	Calcium	75	300	BDTA method	150	
7	Magnesium	30	100	Tribidimetric method	55	
8	Chloride	240	1000	Eliminative method	460	
9	Sulphate	200	400	UV method	300	
10	Iron	0.3	1	SPANDS	0.7	
11	Nitrate	45	120	LDS meter	55	
12	Fluoride	1	1.5	SDDC method	1.2	
13	T.D.S	500	3000	HDS vial	700	
14	Arsenic	0.01	No relaxation		---	

Lab Assistant Chemist
 PH Division Patna



PRINCIPAL
 SR. SEC. DELHI PUBLIC SCHOOL
 FATEHPUR, SHEOHAR



PH Sub Division Patna

